

# PL 415 CDG Technical data sheet

### **General Data**

Prime power (PRP)	416.0 kVA
Prime power (PRP)	333.0 kw
Standby power (LTP)	455.0 kVA
Standby power (LTP)	364.0 kW
Frequency	50Hz
Voltage	230/400 V
Power factor	0.8



### **Engine characteristics**

**CUMMINS** 

**Engine brand** 

=1.g.1.0 D. d.1.d	001 11 11110
Engine model	QSG12 G4
Cylinders	6
Speed	1500 rpm
Cubic Capacity	12.0 L
Air intake	Turbocharged
Oil Capacity	34.1 L
Stage	Stage 2

## **Control system**

Control system brand	Deep Sea
Control system model	6110MKIII
Standard voltage	24 Vdc

### **Cooling system**

Cooling	Water
Heat from radiator	kW
Heat from radiation	kW
Cooling air flow	25920 m3/h

#### **Alternator**

Alternator brand	Stamford
Alternator model	S4L1D-G41
PRP Power	416.0 kVA
LTP Power	455.0 kVA
Phases	3PH/1PH + N
Terminal number	12 nr.
IP Protection	23
Electronic regulator	AS440
Precision	1.5 +/- %

## **Fuel consumption**

Fuel cons. @ 100% (PRP)	81.7 L/h
Fuel cons. @ 75% (PRP)	59.8 L/h
Fuel cons. @ 50% (PRP)	40.8 L/h
Fuel cons. @ 25% (PRP)	21.9 L/h

#### **Exhaust system**

Max intake combustion	6200 Pa
Combustion air volume	1524.0 m3/h
Max exhaust gas temperature	524°C
Exhaust gas flow	3702.0 m3/h
Max back pressure	10200 Pa



# PL 415 CDG Technical data sheet

#### Dimensions & weight (Open frame)

Length	4015 mm
Width	1400 mm
Height	2115 mm
Mass (dry)	3276 kg

#### References

Fuel consumption is nominal and refers to specific weight 0.850kg/l.

Dimensions, weights and other specifications contained in the technical data sheet and related attachments are nominal, subject to tolerances and refer to the model with standard equipment. Any optional and additional equipment / accessories can modify weight, dimensions and performance.

# PRP Prime Power-Continuous power at variable load

The power that a generator can supply in continuous service at a variable load for an unlimited number of hours per year while respecting the maintenance intervals established in the environmental conditions stated by the manufacturer according to ISO8528-1. The average power supplied over time and any applicable overload must be less than the percentages stated by the manufacturer.

#### LTP Limited-time running power-Limited power

The maximum power that a generator can supply for a limited time respecting the maintenance intervals established in the environmental conditions stated by the manufacturer according to ISO8528-1. The number of hours per year is stated by the manufacturer. Overload is not permitted.